



**ADDENDUM NUMBER TWO
CONTRACT FY2020-123**

DATE: March 13, 2020

TO: ALL PROPOSERS OF RECORD

FROM: Lyn Majeski, Purchasing Manager

BID FOR: **SCARBORO PARK UNIVERSALLY ACCESSIBLE PLAYGROUND
REQUEST FOR PROPOSALS**

This addendum forms a part of and modifies the bidding specifications for the above item for the City of Oak Ridge, Tennessee.

ITEM 1 – Questions Received from Potential Proposers

1. Can the existing border timbers be re-used? I forgot, while there last week, to see what condition they are in, but assuming they are fine, it would make \$ sense to re-use them for the outer perimeter unless you didn't want to for some reason? I understand that some type of new bordering system needs to be installed around the accessible paths inside the playground, but wondered about the outer perimeter.
 - a. Actually, that was discussed during the pre-proposal meeting. The plastic timbers are almost 20 years old and suffering from UV degradation. The City has had to replace a number of them as they crack over time. It is an expense and a major headache - one we'd like to avoid by replacing with new (and hopefully improved).