

**SUPPLEMENTAL INFORMATION
ADDENDUM NO. 2**

PROJECT: RFP No. 20-105-002
Professional Services Blue Jay Rd Waterline Extension B

CONTACT: Alison Bruton, Purchasing Agent
912-754-2159 abruton@effinghamcounty.org

DATE ISSUED: March 11, 2020

RFP No. 20-105-002 dated February 6, 2020 is hereby amended as noted herein : BIDDER TO ACKNOWLEDGE RECEIPT OF ADDENDUM BY SIGNING ON THE SIGNATURE LINE BELOW AND INCLUDING A COPY WITH SUBMITTED BID. FAILURE TO DO SO MAY, AT THE OWNER'S DISCRETION, SUBJECT THE BIDDER TO DISQUALIFICATION

- 1) QUESTION: Does the county prefer or intend for the two mains to be on the same side of the road?
ANSWER: Yes
- 2) QUESTION: Is there a side preference for the watermains on each road: US17 & Blue Jay Road?
ANSWER: West side of HWY 17, North side of Blue Jay is preferable, but if necessary, it can be changed.
- 3) QUESTION: Will 10' be the minimum design horizontal separation?
ANSWER: Yes
- 4) QUESTION: Do we need Geotech broken out separately or include in the design services fee?
ANSWER: See Addendum 1, questions 8 and 10. It is necessary to do the design; therefore, it is not a separate line item.
- 5) QUESTION: Do we need private underground location services and if so can this be included in the Surveying Services?
ANSWER: The new Call Before You Dig regulations require the locaters to complete a Design Locate within 15 days of calling in the locate therefore no private locates are necessary.
- 6) QUESTION: If the county chooses the alternate re-use waterline, is the intent to be bid, permit, and construct together as one package? This would assume one bid, one permitting effort, and one construction services.
ANSWER: Yes
- 7) QUESTION: Should we create a separate Attachment A for the alternate Survey and alternate design services?

Addendum No.2
RFP No. 20-105-002
Professional Services Blue Jay Rd Waterline Extension B

ANSWER: Since the water and reuse are going to both be in the HWY 17 and Blue Jay rights-of way and on the same side of the road, there will be no need for extra survey cost. The design of the reuse water will be separate.

8) QUESTION: Is any public participation (open house, public information meeting, county commission meeting) expected? If so should this be included in the design services?

ANSWER: No.

9) QUESTION: Will we be responsible for creating easement plats?

ANSWER: Yes, if easements are needed. But none are anticipated.

10) QUESTION: Does the county prefer to directional bore wetland/stream crossings?

ANSWER: Yes

11) QUESTION: Are we to assume no service connections to 16" mains?

ANSWER: Service Connections will be made.

12) QUESTION: Are any as-builts or design plans for the connecting waterlines available for review prior to bid submittal?

ANSWER: We are unable to locate as-builts at this time.

13) QUESTION: In Addendum 1 under the response to question 4 it states that the survey is anticipated to be from "edge of roadway to centerline of road". Should this read "edge of Right of Way to centerline of road"?

ANSWER: Yes, that should be "edge of right-of-way"

14) QUESTION: In Addendum 1 section 3.1 AMENDED DESCRIPTION AND OBJECTIVES, it states the proposed watermain would be approximately 18,000 feet. The original RFP states the proposed waterline to be approximately 13,000 feet.

- Is the updated approximate length of 18,000 feet correct?
- If so, is there an updated exhibit?
- If it is not the exact same alignment as the reuse waterline, will you need and updated line item cost in Amended Attachment A for Re-Use Water Line surveying costs?

ANSWER: The exhibit was correct the scope has a typographical error. It is the same alignment.

THIS SPACE INTENTIONALLY LEFT BLANK

The Indemnification Section of the RFP (Section 2.15) and Sample Contract (Section 1-9) has been updated as follows:

INDEMNIFICATION To the fullest extent permitted by law, the Contractor shall indemnify and hold harmless Effingham County and its officers, directors, partners, employees, agents, consultants, and subcontractors from and against all claims, costs, losses, and damages for injuries to or death of any person or persons or damage to the property or other rights of any person or persons (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs) arising out or relating to the performance of the work, but only to the extent caused by any negligent or willful act or omission of Contractor, its subcontractors and suppliers, or any individual or entity directly or indirectly employed by them to perform any of the work or anyone for whose acts any of them may be liable. The Contractor's obligation to indemnify Effingham County under this Section shall not be limited in any way by the agreed upon contract price as shown in this Contract or by the scope and amount of insurance maintained by the Contractor.

All other terms and conditions in RFP No. 20-105-002 remain unchanged.

Effingham County reserves the right to reject any and all proposals, to waive any technicalities or irregularities and to award the offer based upon the most responsive, responsible submission.

Please sign receipt of this Addendum No. 2 below:

Print Name

Signature

Date

END OF ADDENDUM NO. 2