

Addendum 3

City of Canton, Ohio
Purchasing Department
218 Cleveland Ave. SW, 4th floor
Canton, Ohio 44702

6th St NW Streetscape, GP 1404

Item/Project

Engineering Department

Responsible Department

2:00:00 PM, 6/14/2023

Bids Due

Bid Proposal Submitted By:

Company Name

Street Address

City

State

Zip

Contact Person

Phone No.

Email Address

Question 1:

Is there an actual layout showing the amount and location of poles that will be installed? I do not even see a column on the unit cost sheet for the fixtures?

Answer:

The locations of the poles are shown on page 6/29 of the plans. There is a pole at STA 12+74.41 20.60' Rt. and at STA 14+08.36 20.10' Rt.

Question 2:

What is the intent of the 3" PVC? Is it filled with conductors or is it empty? Will this be installed in the same trench as the 2" PVC.

Answer:

The conduits will be for future use by others (City). The light poles, fixtures, and conductors will be provided and installed by the city crews. The underground conduits are to be installed in the trench for the curb. They shall be oriented behind the curb.