

MEMORANDUM

TO: All Potential Bidders
FROM: Tim Walling, Purchasing Agent
SUBJECT: Addendum # 1, RFQ 2022-33, Fence Replacement at Pump Stations 38, 50 & 54
DATE: January 19, 2022

The purpose of addendum #1 is to provide a list of the questions that were submitted for this project and provide the answers to those questions.

- Q1. On page 2 (Project Overview) of the solicitation it states that quotes can be sent via email to this email address **OR** submitted through Vendor Registry. On page 6 (RFQ, General Terms) paragraph 1 section B states that quotes must be submitted through Vendor Registry. Can quotes be emailed or should they only be submitted through Vendor Registry?
- A1. Page 2 is correct. Quotes can be either submitted through Vendor Registry or submitted through email. Either way is acceptable. Page 6, paragraph 1B states quotes may be submitted through Vendor Registry. So it's optional.
- Q2. Can you tell us what the wind requirements are for the three locations that get a new fence?
- A2. Fencing shall be able to meet the wind requirements of 140 mph, which is the max listed on the LLR website for Dorchester County under the 2015 International Residential Code.