

POTATO CREEK WWTP EMERGENCY GENERATORS
BID #16-024
CITY OF GRIFFIN

FROM: PARAGON CONSULTING GROUP, INC.
118 NORTH EXPRESSWAY
GRIFFIN, GA 30223

TO: ALL VENDORS OF RECORD

RE: Addendum No. 1, dated June 1, 2016

This Addendum forms a part of the Contract Documents and modifies the original Invitation to Bid dated May 13, 2016.

This Addendum consists of one (1) page.

CONTRACT DOCUMENTS AND SPECIFICATIONS

- Add. 1.1 **Clarification:** An automatic transfer switch (ATS) should be included for both generators.
- Add. 1.2 **Clarification:** The 2,000 Amp breaker specified for the 1,250 KW generator is correct.
- Add. 1.3 **Modification:** The requirement for the Generator Sound Attenuated Enclosure referenced in section 2.5(B) of the specifications has been changed to **75 dBa at 23 feet minimum at full load.**

End of Addendum No. 1