

Tom Green County



113 W. Beaugard
San Angelo, Texas 76903
325-659-6500/Fax 325-659-5441

RFB 21-018 Mullins Crossing Rd – Culvert Replacement

July 28, 2021

ADDENDUM NO 1: Notice to Bidders

1. Additions to Scope:
 - Concrete head wall to be 18” over existing center line of roadway.
 - Head wall shall have a 2’x2’ footing, to prevent “wash-out”.
2. Will paving be required?
TGC Response: No, top of roadway to be finished with limestone base.
3. Contractor is responsible for contacting landowners for access and fencing requirements.
Landowner contact information:
Ronnie Hudson – 325-315-8285
Eddie C. Ordiway – 325-468-2281
4. Will the detour signs need to specify routing? If so, please provide required wording.
TGC Response: Yes, detour signs will need to specify available routes, one placed on each end of Mullins Crossing Rd.

DETOUR:

Douglas Loop to Smith Rd.

or

FM 1692 to McMillan Rd.

Please include this signed addendum with your Response.

Sincerely,



Dustin Klein
Procurement Supervisor
Tom Green County

Company

Date

Signature

Please Print Name and Title