

#### Georgetown County, South Carolina

129 Screven Street, Suite 239 Post Office Drawer 421270 Georgetown, SC 29442-4200 (843) 545-3083 • Fax (843) 545-3500

E-Mail • <a href="mailto:purch@gtcounty.org">purch@gtcounty.org</a> Website • <a href="http://www.gtcounty.org">http://www.gtcounty.org</a>

## **ADDENDUM #2 TO BID #22-066**

BID NUMBER: 22-066 ISSUE DATE: Wednesday, October 5, 2022

(REVISED) OPENING DATE: Wednesday, November 2, 2022 OPENING TIME: 3:30 PM ET

Pre-Bid Conference/Site Inspection: [Voluntary-On Own; Hours of Operation at Landfill M-F 7:30am – 4:30PM]

PROCUREMENT FOR: Gate and Access Control System for Landfill Entrance

This addendum will amend <u>Bid #22-066</u>, <u>Gate and Access Control System for Landfill Entrance</u> originally issued on Wednesday, October 5, 2022. This clarification is being provided to all known and registered correspondents in response to questions received. All addenda and original bid documents are also available online at: <a href="www.gtcounty.org">www.gtcounty.org</a>, select "Bid Opportunities" from the Quick Links section.

**REVISION:** See revised timeline below.

**REVISED Time Line: Invitation for Bid #22-066** 

Advertised Date of Issue:	Wednesday, October 5, 2022	n/a	n/a
<b>Pre-Bid Conference &amp; Site Inspection:</b>	n/a	n/a	n/a
<b>Deadline for Questions:</b>	<b>3</b> )	3:30 PM ET	
Bids Must be Received on/or Before:	• / /	3:30 PM ET	
<b>Public Bid Opening &amp; Tabulation:</b>	Wednesday, November 2, 2022	3:30 PM ET	Hybrid*

**Question 1:** Can you tell us if the CCure system is current on all licensing and capable of expansion?

Answer: The Support license expired in January of this year, 2022. To the best of our

knowledge, the system is capable of expansion.

Question 2: Can you tell us if the access control system is currently in place at the site and standalone or

networked county wide?

Answer: The system at the site is stand alone and is not networked currently.

- **Question 3:** Is this system going to operate on a standalone basis? Is it going to get tied in to the County system or be administered locally by landfill personnel? Who currently administers the CCure System for Georgetown County? Can I get their contact info?
- Answer: The County would like the system to tie into the current CCure System and be administered by the IT department and folks located at the landfill having supervisory privileges to grant and deny badge access as needed.
- **Question 4:** If connecting through the County System, is SSA for CCure Software current? Will programming into County System to be part of this project?
- Answer: The current SSA expired in January of this year, 2022. Yes, the programing of the CCure system to apart of the project if tying into the current system is what the vendor proposes.
- **Question 5:** Will the County require the Software House access control panel to be networked to the county head end and administered from another location?
- Answer: It would be preferred that the Control panel be tied back to the current CCure system to be administered with all other county locations.
- **Question 6:** Will the County require the Software House access control panel to be networked to a standalone computer at the landfill administrated from the landfill only?
- Answer: It would be preferred that the Control panel be tied back to the current CCure system to be administered with all other county locations.
- **Question 7:** Does the County use I-class or Standard HID format of the Landfill gate and Access Control System?
- Answer: The County ACS currently uses HID format. The Landfill gate does not currently connect to the County ACS system and any format.
- **Question 8:** Where are current data connections?
- Answer: The Administrative building is the primary data connection and spokes out to the Scale house and other areas of the property.



## ADDENDUM ACKNOWLEDGEMENT

# Bid #22-066 <u>Gate and Access Control</u> Mandatory Submittal Form

### To be returned with the final proposal submission to Georgetown County.

COM	PANY NAME:	
0	Addendum #1 Received Date:	Initialed By:
0	Addendum #2 Received Date:	Initialed By:
	Addendum #3 Received Date:	Initialed By:
	Addendum #4 Received Date:	Initialed By:
	Addendum #5 Received Date:	Initialed By:
	Addendum #6 Received Date:	Initialed By:

If your Bid submission has already been submitted, acknowledgment may be provided by attaching a digital scan and sending by e-mail. .

### [THE REMAINDER OF THIS PAGE IS INTENTIONALLY LEFT BLANK]