

ADDENDUM NUMBER TWO
FORMER LUPTON CITY MILL ASBESTOS ABATEMENT
FOR THE CITY OF CHATTANOOGA, TENNESEE
Contract Number E-16-006-202

A Site Visit was held at the project location, 1210 Mercer Street, Lupton City, TN 37351 on June 27, 2019 at 10:00 A.M. A sign-in sheet from the meeting is attached.

The following questions have been received regarding the asbestos cleanup at the Lupton Mill Site.

Question 1. Has a structural assessment been performed by a structural engineer to determine the load capacity of the upper concrete slab and to determine it can support equipment and dump trucks?

Answer 1. No. The building is slated to be torn down immediately after the environmental cleanup, so there has been no reason to assess the structural capacity of the slab. We can state that the City has had a rubber tired front end loader with a backhoe attachment on a portion of the slab with no incident. Approximate weight of the machine was 18,000 pounds.

Question 2. There is no water available on site, but it was stated that a fire hydrant can be tapped nearby. Where can we get information and costs associated with this?

Answer 2. Information about fire hydrant meters can be acquired from Tennessee American Water Company at 423-771-4742.

June 28, 2019

/s/Justin C. Holland, Administrator
City Of Chattanooga
Department of Public Works

PROJECT: Former Lupton City Mill Asbestos Remediation

SIGN-IN SHEET

	NAME	COMPANY	PHONE	EMAIL
1	Elizabeth Goss	City	423-643-6191	egoss@chattanooga.gov
2	Alon Oglet	City	423-643-5898	aoglet@chattanooga.gov
3	Josh Kigker	NEO Corporation	423-402-5351	jkigker@neocorporation.com
4	Mark Dempsey	AAT	423-595-0094	markdempsey@alternativations.com
5	Bill Lankford	Trade Environmental	615-308-6268	bill.lankford@trade.com
6	James Mathis	Unique	(423) 704-8232	mathisjames58@yahoo.com
7	Taylor Carver	EAD	615-264-2711	tcarver@eadm.com
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				