



OFFICE OF PROCUREMENT SERVICES
335 FOUR MILE ROAD
CONWAY, SC 29526-6005

AMENDMENT/ADDENDUM No. 1

Posting Date: Monday, April 4, 2022

Solicitation Number: 2122-62VS

Description: HES & SJE Playground Drainage Improvements

ADDENDA: Addenda shall be issued prior to the bid opening date and time for the purposes of modifying or interpreting the Contract Documents through additions, deletions, clarifications or corrections. No addendum shall be issued later than four (4) days prior to the bid opening date except to a) withdraw the Invitation for Bids, or b) to postpone the bid opening date and time. When an addendum is issued for the purposes of postponing the bid opening date and time, the addendum shall establish the new bid opening date and time no earlier than five (5) days after the addendum issue date. Addenda shall be posted on the on-line bidding source(s) stated in the Invitation for Bids. A Bidder shall acknowledge receipt of all addenda issued by identifying the addendum number and the date of issuance with the Bidder's initials in the spaces provided on the Official Bid Form or the bid shall be found non-responsive in accordance with the District's Procurement Code. If this solicitation is amended, then all terms and conditions which are not modified remain unchanged.

INTERPRETATIONS AND CLARIFICATIONS: Requests for additional information or questions regarding error, omission or clarification of any portion of the Bid Documents or the Contract Documents or any addendum, shall be submitted in writing to the District Bid Contact Person stated in the Invitation for Bids by e-mail or facsimile no later than five (5) days prior to the bid opening date and time unless an earlier date is stated on the Invitation for Bids or as may be amended. Any interpretations, corrections, or changes to the Bid Documents or the Contract Documents made in any other manner than by a written addendum shall not be binding, and Bidders shall not rely upon them. Any information given a prospective Bidder concerning a solicitation will be furnished promptly to all other prospective bidders as an addendum to the solicitation, if that information is necessary for submitting offers of if the lack of it would be prejudicial to other prospective bidders. See clause entitled "Bidder Representations." We will not identify you in our answer to your question. The District seeks to permit maximum practicable competition. Bidders are urged to advise the Procurement Specialist – as soon as possible – regarding any aspect of this procurement, including any aspect of the solicitation that unnecessarily or inappropriately limits full and open competition.

BID OPENING DATE AND TIME REMAIN THE SAME

| Question Number | Question | Answer |
|-----------------|---|---|
| 1. | Please confirm/clarify, and provide any specifications or details and the playground equipment manufacturer on the new equipment to be installed if applicable. | See attached PDF file HES Addendum 1-UPDATES a. Page 4, Sheet C4.0 for swing relocation area. b. Page 10, image for new swing set Note: The swing image details the swing style only. It will be a (3) bay (6 swings total) configuration. The size of the post shall be 3.5" or greater. Color to be decided by school prior to contractor ordering equipment. |

| Question Number | Question | Answer |
|-----------------|---|--|
| 2. | If approved, Please provide a detail showing the court striping to the asphalt basketball court as well as the manufacturer and specifications to the goals to be installed. | See attached PDF file HES Addendum 1-UPDATES a. Page 11, basketball court striping. b. Page 12, PR98GHT-Ultimate Hang Time (highlighted) |
| 3. | Will spraying of the work area and tilling/soil conditioning be an acceptable alternative to striping and hauling of the organic material? | Yes, under the assumption that spraying will occur after school has closed June 4th. |
| 4. | Is there a preference on the location of lay-down areas, and sanitary facilities for the duration of construction? | See attached PDF file HES Addendum 1-UPDATES page 13 and attached PDF file SJE Addendum 1-UPDATES page 1. |
| 5. | Please indicate where a preferred permanent water source and power source (110V Outlet for Irrigation Clock) for irrigation can be connected to for both project sites. | See attached PDF file HES Addendum 1-UPDATES page 14 and attached PDF file SJE Addendum 1-UPDATES page 2. |
| 6. | Please confirm the preferred type of sod to be installed. | Certified Tifway 419 Bermuda grass on the respective "playing fields." The other disturbed areas can be hydro-seeded with a pre-approved summer blend. |
| 7. | Will the school district accept a(n) passing/acceptable, inspection by a certified playground inspector as an alternate to a Certification of Approved Installer from a Manufacturer or Supplier Certification of Approved Installer (on manufacturer's, fabricator's or supplier's letterhead) | Yes, each relocated and/or installed playground unit must be inspected after installation by a Certified Playground Safety Inspector (CPSI) |