



RFP#2021-004 YAHOOLA CREEK PARK STREET LIGHTS

ADDENDUM 1

Return to: Lumpkin County Board of Commissioners
Ryan McDuffie, Purchasing Agent
99 Courthouse Hill, Suite D
Dahlonega, GA 30533

Bid Closing Date: July 2, 2021 at 2:00 PM, EST
Bid Issue Date: June 2, 2021
Addendum Issue Date: June 28, 2021 at 5:00 PM, EST
Pages: 1
By: Ryan McDuffie, Purchasing Agent

Vendor Name: _____
(A copy must be attached to the Addenda Acknowledgement)

-
1. Would there happen to be lighting conditions or wattage requirements for the fixtures?
 2. How far up Mechanicsville Rd and Captain McDonald Road does the County want the lights to go?
 - a. The lights should start at the entrance gates on both Captain McDonald and Mechanicsville Roads.
 3. How old is the conduit in the stubs?
 - a. 20+ years.
 4. Are transformers utility company transformers?
 - a. Yes
 5. Is there a light type preference?
 - a. LED
 6. Will there be any light ordinances?
 - a. Light fixtures to be shielded to meet dark skies requirements.

**Please make sure to include your unit prices on your cost proposal to assist with value engineering.

**Please see the updated CAD.