



WILLIAMSON COUNTY GOVERNMENT

Addendum #1

June 2, 2022

Williamson County Public Library PA System Upgrade
Bid Opening June 16, 2022

- Are there any speakers in the sheetrock? *No, they are all ceiling mounted or in the ceiling tiles.*
- Are we supplying new ceiling tiles if these are damaged during installation? *Do not include in your bid price.*
- Does any area need speakers that do not have speakers? *This bid is for replacements only.*
- Do you need the Blue Link option that is specified or do you want to save money and go without it? *Bid per specifications.*
- Are any of the speakers outdoors? *No*
- What will be done with the old speakers? *Williamson County will dispose of them.*
- When does this project need to be completed? *By August 1, 2022, if possible.*
- Are we replacing the amplifiers in the network closet? *Yes*
- Are all the speakers ladder accessible or will we need a lift? *They are all ladder accessible.*
- The specs said to reuse existing cables where possible. Should we include in the bid the potential for having to replace some of the cables? *Base bid is to use existing cables. Include cost per foot for material and installation if any of the cables do need to be replaced.*
- The speaker count of 130 is correct? *Yes*
- What kind of VOIP integration is coming and does it take a SIP interface? *Tesira Forte, yes.*
- Why are you replacing the amplifiers? *We want the entire system upgraded at the same time.*
- Are you open to alternate brands? *If bidding equivalent, include specifications.*
- Can we send you 3 price tier options? *Bid per specifications.*
- Can you use 2x2 tile speakers rather than cut into the tiles? *Bid per specifications.*



Williamson County PA System Upgrade
REVISED

The Williamson County Public Library's main location, 1314 Columbia Avenue, Franklin, TN 37064, is seeking bids to upgrade the facility's PA system.

This upgrade will require:

- One 8 channel 300W Amplifier, Crown DCi 8|300N or equal
- One 2 channel 1250W Amplifier, Crown DCi 2|1250N or equal
- 130 ceiling mounted 6.5in speakers, Community D6 or equal
- 8 surface mount speakers, KUBO5T or equal
- Installation services
- Existing cables will be used where possible, include unit price below if any do need replacement.
- Existing scheduler will be used for pre-recorded announcement.
- Upgrades must integrate with areas that have already been upgraded.

A site visit will be held on June 1, 2022 at 8:00 a.m.. This site visit is not mandatory, but it is highly encouraged that interested bidders attend.

If bidding equal equipment, please include specification sheets.

Total Bid \$ _____

Unit Price- Cost per foot for replacement cable, include material & installation \$ _____

The bidder has received the following addenda:

Addendum # _____ Dated _____
Addendum # _____ Dated _____
Addendum # _____ Dated _____

Company Name _____

Physical Address _____

Remittance Address _____

Authorized Signature _____

Printed Name _____

Phone _____ Fax _____

Email Address _____

Date _____