



# City of Alamogordo

---

Engineering Department □ 1376 E. Ninth Street □ Alamogordo, New Mexico 88310 □ Ph (575) 439-4235 FAX (575) 439-4343

April 3, 2023

To: All Bidders/Plan Holders

Re: **Addendum 1**  
**Public Works Bid No. 2023-001**  
**Rehab Indian Wells Walking Trail**

Addendum Number 1 is issued to provide responses to bidder questions. **The date, time, and location of the BID OPENING remains unchanged.**

1. Question – Is the contractor bound to 7' as most pavers won't pave that narrow?  
Answer – Yes.
2. Question – Can the contractor use the open dirt area next to Pecan Dr. as a staging area?  
Answer – Yes.
3. Question – In the SOW, item j states "Backfill shoulders with base course to subgrade line". Is this meant to be flush with finished pavement grade?  
Answer – Yes.

All other provisions of the Contract Documents shall remain unchanged. This addendum is hereby made part of the Contract Documents to the same extent as though contained in the original documents and itemized listings thereof.

Each bidder is required to acknowledge receipt of each addendum in Section 3 of the Bid Proposal. Failure to do so could render the bid non-responsive.

Plan holders: As a courtesy, please fill out the information below and fax this page back to the City of Alamogordo, Attention: Barbara Pyeatt, Purchasing Manager at 575-439-4117 or replying via e-mail to: [bpyeatt@ci.alamogordo.nm.us](mailto:bpyeatt@ci.alamogordo.nm.us)

Received By (Company): \_\_\_\_\_

Date Received: \_\_\_\_\_

Number of sheets received: \_\_\_\_\_

Time Received: \_\_\_\_\_

Signature: \_\_\_\_\_