

ADDENDUM NO. 3 TO IFB#2020-1918-4304-06
(Questions Emailed)

- Please specify the solvent/cleaning agent to be used to wash the building prior to the Seal Coat.
 - **The County is not recommending or specifying the product below; however, product used should be similar or equal to Krud Kutter Concrete and Driveway Cleaner. It should be biodegradable, earth-friendly, and non-toxic.**
- Can you provide a product recommendation for Silicone with the 20 Year Warranty as required in your specifications?
 - **The County is not recommending or specifying the product below; however, product used should be similar or equal to Dow Corning 795 Silicone Building Sealant.**