



Terry McKee, IT & Procurement Director

901 Broadway N. • Knoxville, TN 37917-6699
 865.403.1133 • Fax 865.594.8858
 purchasinginfo@kcdc.org
 www.kcdc.org

Addendum

SOLICITATION NAME	Renovation Services at Valley Oaks C17008	ADDENDUM NUMBER	C	DATE	10-31-16
--------------------------	---	------------------------	---	-------------	----------

This addendum answers questions raised about this solicitation. To aid in readability, the questions are in black, the answers are in **bolded blue**, and the answers follow immediately below.

Q1	What type of ceiling mount fixture?
	LED Round Surface Mount 13" CFLED150-13-3K-13-WH Model: CFLED150-1 Light source: 32W LED module, 2600 Lumens Color temperature: 3500°K Voltage: 120V Finish: Painted white
Q2	Do you want this in wire mold?
	Wire mold is acceptable.

End of Addendum

