

ADDENDUM NUMBER ONE
EAST CHATTANOOGA YFD CENTER ROOF REPLACEMENT
CONTRACT NO. Y-17-015-201

CITY OF CHATTANOOGA, TENNESSEE

A question was received about the above project:

Q: On the metal roof, do you want snow guards installed? If so, over the door ways only?

A: Due to the possibility of children being all around the building, snow guards need to be installed around the entire metal roof area, not just above the doors. Snow guards should be ColorGard S-5 guards, or pre-approved equivalent, capable of being warranted for the same time period as the roof, and compatible with the roofing warranty.

The bid date for this project is being rescheduled until May 15, 2018 to allow bidders adequate time to adjust their bids for this new information.

May 7, 2018

/s/Justin C Holland, Administrator