



City of Fort Walton Beach, FL

NOTICE TO BIDDERS:

March 11, 2021

Re: ITB No. 21-002: WATERFRONT REPAIRS

ADDENDUM NUMBER 2

Clarification:

1. The use of an impact hammer for installation of pilings will not be allowed for any of the dock or pier installations in this project.”

Questions:

1. Can WearDeck[®] reinforced composite lumber be used as the replacement decking on this project? “WearDeck[®] composite decking is an acceptable alternative to the Trex decking specified in the Sound Park and Liza Jackson Park repairs.
2. Can Eco Pile[®] fiberglass reinforced pilings be used as the replacement pilings on this project? No plastic substitutions for pilings are allowed.
3. What is the current estimate/budget for this bid? Work is needed due to storm damage. No cost estimate is available at this time.
4. Is a Florida Marine contractor’s license required to perform this job?
Yes.

THIS ACKNOWLEDGEMENT MUST BE RETURNED WITH BIDDER PACKAGE.

Issued by: Giuliana Scott, Purchasing Manager

ACKNOWLEDGEMENT:

I hereby certify that I have received ITB 21-002 Addendum #2:

Signature

Date