

ARLINGTON COUNTY, VIRGINIA  
OFFICE OF THE PURCHASING AGENT

INVITATION TO BID NO. 21-DES-ITB-465

ADDENDUM NO. 1

Arlington County Invitation to Bid No. 21-DES-ITB-465 for Gravity One – Phase II – 24 inch water main Project.

The following are answers to the questions received in response to the above referenced ITB:

1. Question: There are existing sanitary sewer laterals identified on the plan view of the documents, but are not identified on the profiles of the new 24” water line. Based on the elevations of the existing sanitary sewer main and proposed new 24” water main, we are anticipating conflicts with at least 6 laterals. Will there be additional compensation to the contractor for any sanitary sewer lateral relocations or for adjustments to the profile of the proposed waterline resulting from these conflicts?

**Response: Yes, there will be compensation, if there is found to be a conflict with the sanitary laterals. It will be paid under Stipulated Pay Item # 8 - SANITARY SEWER SERVICE CONNECTIONS (HOUSE LATERALS) IN ACCORDANCE WITH ARLINGTON COUNTY CONSTRUCTION STANDARDS AND SPECIFICATIONS 02510 (ALL SIZES) as shown on ITB Section V – Attachments and Forms page 83 of 89.**

2. Question: What is the status of the existing 24” line (full or empty) and will the contractor be responsible for disinfecting any portions of the existing line as part of the tie-in process of the new 24” Water Main? **Response: The existing 24-Inch watermain is full. The Contractor will not be responsible for disinfecting any portions of the existing main.**

3. Question: Is an original bid bond required to be sent to your office? **Response: No. Copy of Bid Bond should be submitted with Bid through Vendor Registry**

The balance of the solicitation remains unchanged.

Arlington County, Virginia

Sy Gezachew  
Procurement Officer

**RETURN THIS PAGE, FULLY COMPLETED AND SIGNED, WITH YOUR BID:**

**BIDDER ACKNOWLEDGES RECEIPT OF ADDENDUM NUMBER 1.**

**FIRM NAME:** \_\_\_\_\_

**AUTHORIZED SIGNATURE:** \_\_\_\_\_ **DATE:** \_\_\_\_\_