

**SUPPLEMENTAL INFORMATION
ADDENDUM NO. 1**

PROJECT: RFQ 22-22-001
Portico Addition to Existing Animal Shelter

CONTACT: Alison Bruton, Purchasing Agent
912-754-2159 abruton@effinghamcounty.org


DATE ISSUED: 9/28/2021

RFQ 22-22-001 – Portico Addition to Existing Animal Shelter dated September 1, 2021 is hereby amended as noted herein: BIDDER TO ACKNOWLEDGE RECEIPT OF ADDENDUM BY SIGNING ON THE SIGNATURE LINE BELOW AND INCLUDING A COPY WITH SUBMITTED BID. FAILURE TO DO SO MAY, AT THE OWNER’S DISCRETION, SUBJECT THE BIDDER TO DISQUALIFICATION

- 1) QUESTION: I see the drawings make mention of "specs, t-sheets" on A1.0, but I am not finding it on the effinghamcounty.org or RFQ packet. Could you point me in the right direction?
ANSWER:
No additional specs or conduit needed. Please disregard note: #4 –~~“Provide conduit for all security and surveillance cameras with data network cabling. See specs, T-sheets”.~~
- 2) QUESTION: For paint, is there a finish schedule for us to reference?
ANSWER:
All paint to be exterior grade Sherwin Williams or better, color to match existing building.
- 3) QUESTION: Will the existing concrete footing of the slab be able to support the load from new roofing structure and columns?
ANSWER:
As understood yes. The slab is existing and by others, architect is not knowledgeable as to original installation. Owner will take responsibility for concrete slab.
- 4) QUESTION: Would this cat door work for the project? It meets the requirements of width and height as specified in the drawings from the architect. *vendor submitted document*
ANSWER:
Yes, as long as it is exterior grade this should be fine; lockable.

Addendum No.1
RFQ 22-22-001 – Portico Addition to Existing Animal Shelter

• DIMENSIONS	2.13 x 8.938 x 14.875 inches
• FLAP DIMENSIONS	7 x 11.25 inches
• SURFACE COMPATIBILITY	Wood, PVC, Metal, Vinyl, Aluminum, Fiberglass
• PLACEMENT	Door
• LIFESTAGE	Adult
• BREED SIZE	Medium Breeds
• FEATURES	Insulated, Locking
• MATERIAL	Plastic, Vinyl



5) QUESTION: For the screened porch shelves, should the “3/4” CDX Plywood” to be changed to KDAT wood to match the rest of the specified material?

ANSWER:

Yes, please use KDAT 3/4” plywood for shelving material

6) QUESTION: Clarification for the fan /light kit?

ANSWER:

Owner will provide fan. Contractor to provide electrical, conduit, and J-box for future fan installation.

All other terms and conditions in RFQ 22-22-001 remain unchanged.

Effingham County reserves the right to reject any and all proposals, to waive any technicalities or irregularities and to award the offer based upon the most responsive, responsible submission.

Please sign receipt of this Addendum No. 1 below:

Print Name

Signature

Date

END OF ADDENDUM NO. 1