

PUTNAM COUNTY



**ADDENDUM #4
FOR**

PROJECT NO. 22-42001-002

**PUTNAM COUNTY LANDFILL SUPPLEMENTAL
MAINTENANCE GRADING**

**PUTNAM COUNTY
BOARD OF COMMISSIONERS**

Addendum #4

**Project No. 22-42001-002
Putnam County Landfill Supplemental
Maintenance Grading**

Date: September 29, 2022

Questions and Answers

Question: Does the debris from the borrow area & access road need to be ground up or can we windrow it to the outside? Answer: The debris can be windrowed.

Question: What is the spec for the 42" CMP plain galvanized or coated? Answer: The 42-inch CMP will be coated