


## **ADDENDUM NO. 1**

DATE: March 12, 2020

TO: All Proposers 

FROM: Julie Smith Maxwell, Procurement Specialist

SUBJECT: Addendum No. 1 – Audio Visual System for Knoxville Fire Training Academy

PROPOSALS DUE: March 25, 2020, at 11:00:00 a.m. Eastern Time

This addendum is being published to respond to a question asked by a potential proposer regarding the above-referenced Request for Proposals. This addendum becomes a part of the Contract Document and modifies the original specifications as noted.

**Question 1:** In the bid packet there is a rough drawing layout of the classrooms. Is there a drawing that has dimensions?

Response: Attached to this addendum is a rough drawing layout with dimensions noted.

**Question 2:** The scope calls for consumer grade TV's/monitors. Do you have minimum specifications for the other equipment?

Response: The City provides the following partial parts list. This list is to be considered an example of quality. The City encourages proposers to make recommendations of products that will meet or exceed the needs of the department for the required system upgrade.

1. Blu-Ray, DVD and CD/SD/USB Player with 7.1 Output, HDMI AV Out, LAN Port and RS-232C
2. 8" Two Way Spkr. 120W @ 8 Ohms. 60 Watt 70V/100V multi-tap transformer.
3. PTZ 12x Optical Zoom. 1080p Camera. 6.3 - 72.5 deg Field of View. Outputs HDMI, 3G-SDI, IP Streaming H.264, RS232, RS485 A-In.
4. Standalone H.264 USB Recorder/Player. HDMI IN / OUT. Records MP4 File. 32 GB USB Drive.
5. 5.25" Two Way 70V/8 Ohm Spkr. 10W xfrm./ 60W @ 8 Ohms. 85Hz-18kHz.

**END OF ADDENDUM NO. 1**

