

## ADDENDUM #3 IFB #2018-03

## **Dr. Mellichamp Drive Roadway** and Streetscape Improvements

This addendum is being issued to announce, revise, clarify and address questions or certain issues that have occurred since the solicitation was originally issued.

All contents of this addendum shall be incorporated into the solicitation documents and the ensuing contract with the awarded Contractor. It is the Contractor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid response. Acknowledgement may be confirmed by inclusion of a signed copy of this addendum with the initial bid response. Failure of a Contractor to acknowledge each addendum may prevent the bid from being considered for award and deem the Contractor as non-responsive.

Addendum, revised forms and documents attached hereto shall not be altered and attached to bid submittals in their original format.

No further questions or request for clarifications, submitted by potential vendors for this solicitation, can be accepted.

## **QUESTIONS AND ANSWERS FROM POTENTIAL VENDORS:**

Question # 1 - While going over the plans again for the above referenced project I noticed on the Utility Plans C3.1 & C3.2 reference to a 4" PVC-C900-DR18 water line capped on both ends for a future fire lateral, several 2" & 4" conduit sleeves, and capping several 2" water lines but there isn't any bid items to cover paying for this work. Is this part of this project or will it be done in the future?

<u>Answer # 1</u> – Yes, these items are part of the project and shall be included in the bid. Attached is a revised Bid Form – Unit Price Schedule which includes the following:

- 4" PVC-C900-DR18 water line is Line Item #2 (Miscellaneous)
- 2" & 4" Conduit sleeves were added this morning as Line Item 3 & 4 (Miscellaneous)
- 2" Caps is Line Item #11 (Add Alternate #1 Water)

Sealed bids will be received by the Town of Bluffton until 2:00 p.m. on July 6, 2017.

All prospective Respondents are reminded and hereby instructed not to contact any member of the Town of Bluffton Council, Town Manager or Town of Bluffton staff members, other than the noted contact person OR the Town's Purchasing Administrator regarding this IFB or their response at any time during the solicitation and award process. Any such contact shall be cause for rejection of your submittal.

## ALL OTHER SPECIFICATIONS, TERMS AND CONDITIONS REMAIN UNCHANGED RECEIPT OF THIS ADDENDMU IS HEREBY ACKNOWLEDGED

	NAME OF BUSINESS	
BY:		
	SIGNATURE	
	NAME AND TITLE	