



Terry McKee, IT & Procurement Director

901 Broadway N. ♦ Knoxville, TN 37917-6699
 865.403.1133 ♦ Fax 865.594.8858
purchasinginfo@kcdc.org
www.kcdc.org

Addendum

SOLICITATION NAME	PTAC Units Q1720	ADDENDUM NUMBER	1	DATE	02-08-17
--------------------------	------------------	------------------------	---	-------------	----------

This addendum answers questions raised about this solicitation. To aid in readability, the questions are in black, the answers are in **bolded blue**, and the answers follow immediately below.

Q1	What is the specified brand(s)?
	<p><u>Midea</u> Model Number: MP12HMB63 12,000 BTU PTAC with 3.5 kw Heat & Heat Pump with a 20 Amp Power Cord</p> <p><u>Midea</u> Model Number: MP12HMC62 12,000 BTU PTAC with 5 kw Electric Heat & Heat Pump with a 30 Amp Power Cord</p> <p><u>Trane</u> Model Number: PTHF1201HAA 12,000 BTU PTAC with 3.5 kw Heat & Heat Pump</p> <p><u>20 AMP Power Cord</u> Model Number: PWR00288</p> <p><u>30A Power Cord</u> Model Number: PWR00290</p> <p><u>GREE</u> Model Number: ETAC-12HP230V20A-A 12,000 BTU PTAC with 3.45 kw/ 20 A 5 KW/30 Amp Heat & Heat Pump with 3.45 kw/ 20 A 5 KW/30 Amp</p> <p>E2 Cord-230V 20 Amp E2 Cord-230V 30 Amp</p>
Q2	Will KCDC consider equals?
	<p>KCDC will consider equals provided the supplier sends an email request for approval with complete information about the equal item to purchasinginfo@kcdc.org at least five business days before the due date. KCDC reserves the right to request samples as part of the evaluation.</p>

End of Addendum

