

## **ADDENDUM NO. I**

**Date:** August 19, 2022  
**To:** All Bidders  
**From:** Penny Owens, Purchasing Agent, City of Knoxville  
**Subject:** Addendum No. I – Waterfront Drive Roadway Improvements Phase III

**Bids to be Opened:** August 24, 2022 at 11:00 am (Eastern Time)

This addendum responds to questions from potential bidders and provides clarification to the specifications. This addendum becomes a part of the Contract Document and modifies the original specifications as noted.

### Questions

1. Q: Who is responsible for procuring permits?  
A: The contractor is responsible for procuring any necessary permits.
2. Q: Who is responsible for staking out all sidewalks, curbs, etc?  
A: The City of Knoxville Engineering Department will be providing all survey stakeout on this project.
3. Q: Who is responsible for 3<sup>rd</sup> party testing?  
A: The contractor is responsible for all 3<sup>rd</sup> party testing.
4. Q: Will a video of the residence landscaping be required or will COK accept photos?  
A: The contractor shall use whatever methods they prefer to document before and after conditions.
5. Q: Can you clarify the scope of work at the green areas between public sidewalk and street curbs along Waterfront, Langford, Claude, and Barber?  
A: The contractor shall install topsoil, seed, and straw in the areas between the sidewalk and curb per the project specifications.
6. Q: There are (8) type B and (3) type A fixtures shown on the plans. The bid schedule calls for (11) type B fixtures and there are no A type fixtures listed in the Bid Schedule nor on the fixture schedule. Is this a typo and they should all be type B?  
A: All 11 fixtures shall be type B per the Bid Schedule and fixture schedule.

7. Q: Direct boring under Langford was mentioned in the pre-bid meeting. Who is responsible for this, GC or COK? There was no items for direct boring listed in the Bid Schedule.

A: The contractor shall direct bore the conduit for the electric service relocation work shown on Plan Sheet E2. Any costs associated with the installation of this conduit shall be included in the unit price of the conduit and paid for by the linear foot.

**END OF ADDENDUM NO. I**