

ADDENDUM NO. 1

APRIL 28, 2020

CITY OF ORANGE BEACH, ALABAMA

RECREATION CENTER DRAINAGE AND TENNIS COURT IMPROVEMENTS

PLAN SET

Sheet 10 of 29:

Delete: Sheet 10 of 29 – “POND #2 SHEET ” dated and signed April 7, 2020 as there is a typographic error on the outfall detail.

Add: Sheet 10 of 29 – Revised “Pond # 2 Sheet” dated and signed April 24, 2020

Sheet 18 of 29:

Delete: Item 3 which currently reads “3 inch net post with 3-1/2 inch galvanized steel sleeve”

Add: Item 3 shall read “2-7/8 inch net post with 3 inch PVC sleeve”

Sheet 29 of 29:

12-01

Delete: 12-01 which currently reads: “BENCH, TO BE PROVIDED BY OWNER. MOUNT / WELD TO SHADE STRUCTURE POST ASSEMBLY. “

Add: 12-01 REVISED: “BENCH, TO BE PROVIDED BY OWNER. OWNER TO MOUNT / WELD TO CONTRACTOR-INSTALLED SHADE STRUCTURE POST ASSEMBLY AFTER INSTALLATION.”

12-02

Delete: 12-02 which currently reads: “SHADE STRUCTURE, REPLACE EXISTING FABRIC WITH SIMILAR COLOR, STYLE, & TEXTURED FABRIC, RE: HDSC PLAN FOR POST / SLEEVE ASSEMBLY DETAIL.”

Add: 12-02 REVISED: “SHADE STRUCTURE, REPLACE EXISTING FABRIC WITH SIMILAR COLOR, STYLE, & TEXTURED FABRIC, RE: HDSC PLAN FOR POST / SLEEVE ASSEMBLY DETAIL. CONTRACTOR TO SALVAGE, PROVIDE REPLACEMENT, AND RE-INSTALL.”

12-03

Delete: 12-03 which currently reads: "TRASH RECEPTACLE."

Add: 12-02 REVISED: "TRASH RECEPTACLE, TO BE PROVIDED AND INSTALLED BY OWNER."

SPECIFICATIONS

Tennis Court Fence Clarification: Aluminum Chain Link Fence coating, core and finish shall be:

Fused Bonded, 9c8f x 1-3/4"

APPROVED EQUALS

Tennis Court Surface:

- Plexipave Hardcourt Surface System
- Acrytech Sport Surfaces, Max Cushion **(Requires an additional coat of Acrylic Resurfacer prior to installation of cushion coatings)**

Tennis Court Lights:

- LSI Blade (XARL) LED Light Fixture



Authorized

4-28-20

Date

Acknowledgement

Date