



## SOLICITATION ADDENDUM

City of Leesburg | Purchasing Division  
204 N. 5<sup>th</sup> Street | PO Box 4906030  
Leesburg, FL 34749-6030  
Phone: (352) 728-9880 | [purch@leesburgflorida.gov](mailto:purch@leesburgflorida.gov)

### ADDENDUM NO. 1

Date Issued: March 15, 2018

Solicitation: **180171 – Water Tank Washout & Inspection**

The following changes, revisions, additions and information are made to solicitation document 180171. Bidders shall take all information into account when preparing their bid response.

Language removed from the specification is shown as ~~strike through~~. Language that is added or inserted shown as ***bold, italic and underlined***.

### **REVISION TO SCOPE OF WORK**

#### **SW-4 HYDRO-PNEUMATIC TANK CLEANING**

##### ***4.3 Interior Cleaning***

***4.3.1 Tank will be drained by City, Contractor will be responsible for power wash cleaning the interior after drained.***

***4.3.2 The tank interior will need to be disinfected to 50 ppm and Bacteriological Samples taken before it can be put back into service. Contractor will disinfectant and City Personnel will collect samples.***

#### **SW-5 GROUND STORAGE TANK CLEANING**

##### **5.2. Interior Cleaning**

~~5.2.1. Tank will be drained by City, Contractor will be responsible for power wash cleaning the interior after drained.~~

~~5.2.2. The tank interior will need to be disinfected to 50 ppm and Bacteriological Samples taken before it can be put back into service. Contractor will disinfectant and City Personnel will collect samples.~~

***5.2.1 Tank will remain filled, Contractor will be responsible for vacuuming the interior of tank as it remains in service. All interior work must be completed by a certified diver entering the tank.***

---

All other elements of the Solicitation Document remain unchanged.

**Please direct any questions related to this addendum to the Purchasing Office.**

---

### **ACKNOWLEDGEMENT**

It is the vendor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid or proposal response in the space provided on the Certification/Addendum Acknowledgement Form included in the original solicitation document. Failure to do so may subject the bidder to disqualification.