

Server Backup Generator for Roane County School District ADDENDUM NO.1 ESG Project No.21605

The following items shall be as noted below:

- A. Pre-Bid will be held at the project site on Tuesday May 11, 2021 at 1:30. The address is 105 Bluff Rd, Kingston, TN 37763.
- B. Reference Specifications Section 26 32 13 Natural Gas Engine Generators:
 - 1. Part 2 Products, 2.1, B: add 4. MTU-Solutions

NOTE:

Equipment other than specified and added in addendums will be considered for the project, only if it meets or exceeds the requirements of the specified equipment design criteria. The previously listed manufactures equipment may be submitted for review by the designer during the shop drawing phase of the project, however, this does not constitute the pre-approval of the submitted equipment, only the manufacturer brand name. All proposed alternate equipment shall be equivalent to the basis of design or better in all respects as to performance, quality of construction, finish, sustainability for the application and overall appearance and dimensions.

Engineering Services Group, Inc.

Prepared by: William R. Moore, Jr.

Reviewed by: Edward C. Henderson, Jr, P.E.

Date: May 5, 2021

