

Addendum No. 3

FOR

City of Lake City Lake City Gateway Airport



FUEL FARM

City ITB: 006-2018

PREPARED BY:



PASSERO ASSOCIATES, LLC
13453 N. MAIN STREET – SUITE 104
JACKSONVILLE, FL 32218

ADDENDUM NO. 3

Your attention is directed to the following interpretation of changes in and additions to the Contract Documents for the Fuel Farm project. This Addendum is part of Contract Documents in accordance with the provisions included in Section GP-20.

BIDS ARE DUE Tuesday, January 16, 2018 at 2:00 PM, AS LISTED IN ADDENDUM NO. 2.

I. ITEMS AMENDED/ADDED TO THE CONTRACT DRAWINGS:

1. **REPLACED** Sheet 9, Grading, Drainage & Utility Plan. Additional stormwater retention pond area added. See attached.

II. QUESTIONS FROM BIDDERS & RESPONSES

The following are responses to questions received in writing.

QUESTION 1: *The stainless steel enclosure is shown in the explosion proof area. So this being the case that box has to be explosion proof. The power panel was set just outside the explosion proof zone. Can this 4 x 4 x 6 box also be set outside the zone?*

RESPONSE: The 4 x 4 x 6 box IT closet will not be relocated and shall be explosion proof.

QUESTION 2: *How many copies of the bids will we need to provide?*

RESPONSE: Three copies of the bid shall be sent to arrive at the specified time and date for receipt of bids

END OF ADDENDUM No. 3

