

Town of Summerville

RFP – Upfit Fire Station 1

Q&A 1.31.2022

1. Will a bid bond be required? If so, what % of bid? **Bid bond is not required**
 2. Please confirm bid date is Feb 24th at 10AM. **Yes**
 3. Do we assume that in any area to receive wall paint, the doors and frames in these areas are to be painted as well? **Correct**
 4. Please provide specs and quantities for the lockers. **Included in Pre-bid meeting notes**
 5. Please confirm that we will be installing new floor in the Kitchen and eating area. The SOW only refers to the eating area. **Yes, to match flooring in eating area**
 6. Please confirm the new countertops should be level 1 solid surface. **Yes**
 7. Confirm that there is not painting in the day room. **Yes**
 8. Please provide specs for lighting at Apparatus Bay **4' or 8' long High-Bay LED light fixtures in non-conditioned rooms providing min. avg. of 200 lux.**
-
- Electrical and mechanical permits will be required at no cost for the project.
 - Business license is required.