

BID NUMBER: 0070

ADDENDUM 1:

BID TITLE: UCHS FOOTBALL FIELD FENCE

QUESTION 1: Is it 9 gauge before coating or 9 gauge after black coating?

ANSWER 1: 9 gauge after black coating.

QUESTION 2: Does the fence have top rail or tension wire at top?

ANSWER 2: top rail is 1 5/8" sch 20; line posts are 2" sch 20

QUESTION 3: What size diameter post for gate, corner and line post?

ANSWER 3: Nothing below 3" diameter - with few exceptions on double drive gate sizes to be approved by UCPS (bigger the gate the bigger the post required)

PLEASE NOTE THE FOLLOWING CHANGES IN THE LANGUAGE OF THE BID SPECIFICATION

DURHAM DRIVE SIDE FENCING

6' Commercial Grade Black Chain Link, 9 gauge

Fence will run from the last brick corner column toward the wooded area approx. 60' then toward the football bleachers approx. 650' behind the press box on the bleachers to allow mower to access rear of bleachers - ~~installing a 8' gate to allow access to the field light electrical boxes.~~ Also includes a run of approx. 350' toward the rear corner on the far side of the bleachers.

Addition to specification:

Install a 14' gate (two seven foot sections) near the front gate to allow for construction entrance. This side fence shall be run behind electrical poles near the stadium