

Addendum 2

City of Canton, Ohio
Purchasing Department
218 Cleveland Ave. SW, 4th floor
Canton, Ohio 44702

STA 15th St SW Bridge Replacement Project - GP 1299

Item/Project

Engineering Department

Responsible Department

2:00:00 PM, 6/22/2023

Bids Due

Bid Proposal Submitted By:

Company Name

Street Address

City

State

Zip

Contact Person

Phone No.

Email Address

Question 1:

Per drawing 35/53, is the specified depth of sheeting to elevation 975' with $S = 37.3 \text{ in}^3/\text{ft}$ designed as a cut off wall for the cofferdam?

Answer:

The correct page is 29/47. The questioner referenced page 35/53, which is from a set of plans included in the original bid which was posted back in March. The plans have changed on this current second bid advertisement.

The Minimum embedment of the Temporary Cofferdam is at Elevation 975 Ft. The $S = 37.5$ cubic inch/inch is as per the plan drawing. Interpolation and extrapolation of the boring logs should confirm this information. The contractor must accept this information as independent factual assumption and bid appropriately.