



THE CITY OF DAYTONA BEACH OFFICE OF THE PURCHASING AGENT

Post Office Box 2451
Daytona Beach, Florida 32115-2451

Phone (386) 671-8080
Fax (386) 671-8085

ADDENDUM NO. 6

DATE: August 2, 2018
PROJECT: ITB 0318-2210
NOVA ROAD MEDIAN LANDSCAPING

OPENING DATE: August 16, 2018

This addendum is hereby incorporated into the Bid Documents for the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~striketrough~~.

1. Question: There are (3) large drainage structures North of ISB that will not allow irrigation pipe, wire and heads to be installed as shown on the irrigation plans. How would you like us to navigate this conflict? The existing drainage structures are from curb to curb and you can't directional under the structure due to the canals concrete cap.

Answer: The concrete along the sides of the structures were found to be only 3 or 4" thick and were probably placed along the sides for maintenance reasons. City forces will have one side removed prior to start of construction. Therefore, there will be ample room to install the new irrigation pipe, wires, and heads past the 3 structures.

2. All other terms and conditions remain the same.

The Bidder shall acknowledge receipt of this addendum on the Bid Proposal Form.

The City of Daytona Beach

Kirk Zimmerman, CPPB
Buyer