



**IFB #338-19 VETERANS MEMORIAL PARK – PAVILION,
PLAYGROUND AND MULTI-PURPOSE FIELD
ADDENDUM #4**

Bid Opening Date: ~~May 30, 2019, at 2:00 PM, EST~~ June 4, 2019, at 10:30 AM, EST
Bid Issue Date: April 25, 2019
Addendum Issue Date: May 24, 2019, at 12:07 PM, EST
By: Melissa Hawk, Purchasing Manager

The following are amendments to the IFB #338-19 Veterans Memorial Park – Pavilion, Playground and Multi-Purpose Field:

1. The original bid opening date and time of May 30, 2019, at 2:00 PM, EST has been changed due to the necessity of this addendum #4. The new bid opening date and time will be June 4, 2019 at 10:30 a.m., at 25 Justice Way, Dawsonville, GA 30534.
2. All other dates, terms and other scope of services remain the same as posted in the IFB document.

The following are questions and answers to the IFB #338-19 Veterans Memorial Park – Pavilion, Playground and Multi-Purpose Field:

QUESTION: Addendum 3 calls out a slope of 2:1 behind the wall of stone backfill but the plan calls out a 1:2 slope. 1:2 is a lot steeper than a 2:1 and a lot less stone. Can we get a clarification?

ANSWER: The correct slope is shown on the plans as 1:2 and overrides information as provided to Purchasing regarding this question on Addendum #2.

Company Name

Signature of Authorized Representative

Title

Date

THIS DOCUMENT MUST BE COMPLETED AND SUBMITTED AS PART OF YOUR PROPOSAL