



City of Conroe
PO Box 3066
Conroe, Texas 77305

ADDENDUM NO. 1

DATE ISSUED: June 18, 2020

PROJECT NAME: RFQ 0626-2020 Cabling at the City of Conroe Gun Range

This revision shall be considered part of the contract documents for the above named project and shall be incorporated integrally with the previously issued documents. Wherein provisions of the revisions differ from the provisions of the original documents and/or the provisions of previously issued addendum, the provisions of this revision shall govern and take precedence.

Q & A: Gun Range RFP Questions and Answers

- Was there an estimated cost for this project?
 - No
- What kind of cabling for the speakers?
 - Speaker cabling is 1 CAT6 per location.
- Campus fiber that connects to existing exterior City owned fiber.
 - Quote for campus fiber should be compatible for splicing to the existing exterior fiber which is Corning Single mode SM Ultra Altos with binder less fast access - 17901526 (12 count).
 - Attach cable spec sheet.
- Maintenance Bldg 9U cabinet size
 - Cabinet should accommodate a switch with a depth of 12.5" plus cable connections. Approximate depth is 16" inches.
- Fiber Testing
 - Exterior fiber is a 12-count fiber with 6 strands going to the Gun Range and 6 strands going to the Waste Water Treatment Plant which is past the Gun Range on the same road.
- Cabling on the 1st Floor
 - Cables should terminate in the IDF on the 1st floor.
- Floor box cabling information
 - Floor box cabling should terminate in the IDF of the floor where the box exists.

By the signature affixed below, Addendum No. 1 is hereby incorporated into and made a part of the above referenced solicitation.

ACKNOWLEDGED

Authorized Signature



CITY OF CONROE

Est. 1904

Printed Name

Respondent/Contractor

Date

Kristina Colville

Kristina Colville, Purchasing manager