

**ADDENDUM SEVEN
POLE BARN AT STORAGE YARD FOR MBWWTP
CONTRACT NO. W-19-004-201
CITY OF CHATTANOOGA, TENNESSEE**

The following changes shall be made to the Contract Documents, Specifications, and Drawings:

1. Q & A

Q. Is metal siding to be included on all 4 sides?

A. Metal siding is only required for the end bays of the building. The long dimensions of the building are to be open.

August 13, 2020

/s/ Justin C. Holland, Administrator
City of Chattanooga
Department of Public Works