



ADDENDUM NO. 2

Issue Date: February 10, 2022

Project Name: Utilities Water/Wastewater Fire Systems Improvements

Bid Number: 2022031

Bid Opening Date: February 15, 2022

This addendum is being released to answer questions received to date.

The information and documents contained in this addendum are hereby incorporated in the invitation to bid. **This addendum must be acknowledged where indicated on the bid form, or the bid may be declared non-responsive.**

Questions and Answers

Please confirm that conduit and back boxes are the responsibility of the contractor. If yes, please

1. confirm that pvc and/or emt conduit are acceptable. **Yes, they are the responsibility of the contractor and either are approved but they must meet Building Codes.**