



Florence County Government
Procurement Department

August 30, 2017

ADDENDUM NO. 1- REMOVAL OF TWO (2) UNDERGROUND STORAGE TANKS (USTs) AND TWO (2) FUEL DISPENSING SYSTEMS AT THE COUNTY COMPLEX (BID NO. 06-17/18)

THE FOLLOWING CHANGES TO THE SCOPE OF WORK IS TO BE ADDED TO THE INVITATION TO BID DOCUMENT:

15. The successful vendor shall collect samples from the UST tank pit and evaluate soils for the presence of impact using a photoionization detector (PIS) and use an approved SCDHEC method/procedure for obtaining confirmation sample results in the field, in lieu of off-site laboratory analysis when over excavation is not required.

16. The successful vendor shall collect two (2) soil samples from directly beneath the mid-line location of both tanks. Sample shall be collected no deeper than two feet into the native soil.

NOTE: Power will be terminated at both fuel dispensing systems prior to the start of the work.

NOTE: The County will designate an area near the fuel dispensing system to be used to handle the temporary excavated soil and as a lay-out area for equipment and removed materials.

PLEASE ACKNOWLEDGE THIS ADDENDUM BY SIGNING BELOW AND SUBMIT IT WITH YOUR BID.

I have read and acknowledged this addendum for bid no. 06-17/18.

Authorized Signature

Printed Name

Date

Company Name

County Complex
180 N. Irby Street MSC-R, Florence, SC 29501 Telephone (843) 665-3018 Fax: (843) 664-9668