

ADDENDUM NO. III

DATE: March 10, 2017

TO: All Proposers

FROM: Janice McClelland, Assistant Purchasing Agent

SUBJECT: Addendum No. 3 – Fall Arrest System

PROPOSALS TO BE OPENED: March 17, 2017, at 11:00:00 a.m.

This addendum becomes a part of the Contract Documents and modifies the original specifications as noted.

Questions Submitted to the Office of the Purchasing Agent

Q1. Please confirm that it will be acceptable to utilize boom lifts and fork lifts on the ice surface during installation.

A1. The contractor will be permitted to drive fork lifts and boom lifts onto the ice.

Q2. Please confirm that the contractor will have uninterrupted access to the arena, Monday through Saturday, during normal business hours, for the duration of the installation.

A2. Because of scheduling commitments, the City cannot make this guarantee; however, there is a high probability that there will be no interruptions during the months of May and June.

Q3. Please confirm the quantity of user equipment to be provided.

A3. Ten.

Q4. Please provide detailed structural plans of the roof framing and the back wall at the spotlight level.

A4. Structural plans/drawings are not available.

Q5. Please confirm that if the structural analysis determines that the building is structurally inadequate to support the fall protection loads, the City will undertake any required design and installation of structural reinforcement separate from this contract.

A5. Pricing submitted in the proposal must be itemized by these key deliverables (please refer to Paragraph 5.3 of the RFP):

Structural analysis and report
Design, delivery, and installation
Training

Should the structural analysis determine that the building is structurally inadequate to support the fall protection loads, the City will decide at that time if the project is to proceed further. If the City elects to stop the project, the contractor shall be paid for the structural analysis/report at the contracted price and the contract terminated. If the City should decide to obtain the design and installation of any structural reinforcement necessary to accommodate a fall protection system, that work will be undertaken by the City separate from this contract.

END OF ADDENDUM NO. III