

ADDENDUM #2

TO

SPECIFICATION AND CONTRACT DOCUMENTS

November 13, 2019

TO: ALL PLAN HOLDERS

FOR: ITB-003-2020 WATER PRODUCTION WELL #1 PUMP REPLACEMENT

The purpose of addendum #2 is to answer remaining questions received prior to the deadline for questions.

Contractor must acknowledge receipt of all addenda with submittal on the form provided herein.

1. What is the address of the Price Creek Water Treatment Plant?

Answer: 144 SE Ozone Loop, Lake City, FL 32025

2. What is the well depth (for cleaning purposes)?

Answer: The well depth is three hundred and fifty (350) feet.

No. 1 Dated_____

Signature:_____

No. 2 Dated_____

Signature:_____

THIS FORM MUST BE INCLUDED WITH PROPOSAL