

**MANGINI**

ARCHITECTURE  
INGENUITY

McLAIN BARENG MORRELLI

MANGINI ASSOCIATES INC.  
4320 West Mineral King Avenue  
Visalia, California 93291

www.mangini.us  
(559) 627-0530 Office  
(559) 627-1926 Fax

**REQUEST FOR INFORMATION**

**RFI NO.**

TO: Mangini Associates Int.  
Attn: EDGAR / OMAR F

PROJECT: AH Ed complex

DATE: 3/26/20  
ARCHITECT'S RFI NO.: \_\_\_\_\_  
PROJECT NO.: \_\_\_\_\_  
DSA APPL. NO.: \_\_\_\_\_

Subject: #1 Can you clarify who will install the rough wall and finish plumbing of the relocate buildings?  
Plan/Spec. Ref: \_\_\_\_\_  
Question: \_\_\_\_\_

Suggestion: #2. There is a note on P-2 stating Contractor is to provide 4" S and 1 1/2" CN stub outs (TYP). OWNER IS TO connect restroom plumbing to stub outs (TYP). Per our conversation at the initial job meeting, ITC here under the impression that the contractor was going to install the rough wall plumbing and finish plumbing. If so, will sub-flux work need to be installed as well? There is a rough-in detail on P-3 with no pipe sizes.

Attachments: \_\_\_\_\_

- Contractor's Contract Status:**
- No change in contract time of sum required
  - Change in contract time may be required
  - Change in contract sum may be required

The undersigned certifies that the Contractor has thoroughly reviewed all Contract Documents and determines that the information requested is not contained in the Contract Documents.

By: Alex C Company: Optimum plumbing Title: owner  
Phone: 559-991-6605 Fax: \_\_\_\_\_ Email: \_\_\_\_\_

Response: #1 Contractor is to provide all plumbing work as described in spec section 01 1110 paragraph 1.2

#2 Contractor is to provide ALL plumbing work for a finished working system as discussed in the pre-bid meeting.

By: Edgar Sanchez Date: 3.26.20  
MANGINI ASSOCIATES INC.

CC: \_\_\_\_\_