



THE CITY OF DAYTONA BEACH
OFFICE OF THE PURCHASING AGENT

Post Office Box 2451
Daytona Beach, Florida 32115-2451

Phone (386) 671-8080
Fax (386) 671-8085

ADDENDUM NO. 1

DATE: June 27, 2018

PROJECT: ITB 0218-1790
HIGH SERVICE PUMP MOTOR, BASE, AND COUPLING REPLACEMENT

OPENING DATE: ~~June 28, 2018~~ July 6, 2018

This addendum is hereby incorporated into the Request for Proposal for the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~strikethrough~~.

1. The Bid Opening Date is hereby CHANGED from ~~June 28, 2018~~ to July 6, 2018.
2. The following is ADDED to the Scope of Work as the new 4th and 5th paragraphs:

"The Contractor will be present at motor start up. During the startup process, the Contractor will verify correct amperage, voltage, and rotation. The Contractor will record amperage and voltage after 15 minutes of run time to ensure the motor meets specifications.

"The Contractor may utilize the existing hoist in the pump building during removal and installation."

3. Section 9, Effective date and Term is hereby CHANGED as follows:

"CONTRACTOR will commence work upon issuance of a Notice to Proceed and will complete the work within ~~60~~ 90 days from the effective date of the Notice to Proceed."

4. A photograph of the motor plate from the previous motor is ATTACHED for Bidders' information.
5. The Mandatory Pre-Bid Sign In Sheet is ATTACHED.
6. All other terms and conditions remain the same.

Proposers shall acknowledge receipt of this addendum in their Proposal Transmittal letter.

The City of Daytona Beach

Joanne Flick, CPPO, CPPB
Purchasing Agent

Addendum No. 1 ITB 0218-1790 June 27, 2018
Page 1 of 1

Remember to register with the City of Daytona Beach at www.vendorregistry.com to be notified of future bid opportunities with the City. As of 9-30-18 we will no longer be using our current system.