



Georgetown County, South Carolina

129 Screven Street, Suite 239
Post Office Drawer 421270
Georgetown, SC 29442-4200
(843) 545-3083 • Fax (843) 545-3500
E-Mail • purch@gtcounty.org
Website • <http://www.gtcounty.org>

ADDENDUM #3 TO BID #22-015

BID NUMBER: 22-015

ISSUE DATE: Tuesday, March 22, 2022

OPENING DATE: Wednesday, March 30, 2022

OPENING TIME: 2:30 PM (ET)

Pre-Bid Site Inspection: [By Appointment Only]

PROCUREMENT FOR: Retreat Park Well Replacement

This addendum will amend **Bid #22-015, Retreat Park Well Replacement** originally issued on Wednesday, February 25, 2022. This clarification is being provided to all known and registered correspondents in response to questions received. All addenda and original bid documents are also available online at: www.gtcounty.org, select "Bid Opportunities" from the Quick Links section.

The department wishes to correct the question and response issued in addendum #2 for question #3 and question #6. Please see corrected responses below:

Corrected Question 3: What is the screen slot required?

Correct Response: See #3 in Irrigation Well Notes.

Corrected Question 6: What type of PVC casing and screen does Georgetown County predicting to use for this well?

Correct Response: SDR 17 casing, screen type TBD by driller, see #3 in Irrigation Well Notes. See also revised bid form in Addendum #2 which adds welded carbon steel casing in lieu of PVC casing as an Alternate #1 item.



ADDENDUM ACKNOWLEDGEMENT

BID #22-015 Retreat Park Well Replacement Mandatory Submittal Form

To be returned with the final proposal submission to Georgetown County.

COMPANY NAME: _____

Addendum #1 Received Date: _____ Initialed By: _____

Addendum #2 Received Date: _____ Initialed By: _____

Addendum #3 Received Date: _____ Initialed By: _____

Addendum #4 Received Date: _____ Initialed By: _____

Addendum #5 Received Date: _____ Initialed By: _____

Addendum #6 Received Date: _____ Initialed By: _____