



City of Alamogordo



Engineering Department □ 1376 E. Ninth Street □ Alamogordo, New Mexico 88310 □ Ph (575) 439-4220 FAX (575) 439-4343

March 22, 2019

To: All Bidders/Plan Holders

Re: **Addendum No. 1**
Public Works Bid No. 2019-001
Canyon Road Water Line Extension

Addendum Number 1 is issued to provide changes and/or clarifications to the referenced Public Works Bid as per the following:

The CID Licensing Requirement for this project is GF-9 or GF-98 for water line work and GA-1 or GA-98 for pavement-related work.

Question: If, in vertically deflecting the proposed water line to avoid the existing gas line(s), can the increased depth of the water line be continued to prevent lowering effluent reuse line(s) and existing water line(s)?

Answer: This can be considered to prevent lowering of existing water/effluent reuse lines but the impacts to the trench section/widths would also need to be considered. This can be addressed during construction.

The Pre-Bid Meeting Agenda and Sign-In Sheet are attached.

Each bidder is required to acknowledge receipt of each addendum in Section 3 of the Bid Proposal, failure to do so could render the bid non-responsive.

Plan holders: As a courtesy, please fill out the information below and fax this page back to the City of Alamogordo, Attention: Barbara Pyeatt, Purchasing Manager at 575-439-4117 or replying via e-mail to: bpyeatt@ci.alamogordo.nm.us

Received By (Company): _____

Date Received: _____

Number of sheets received: _____

Time Received: _____

Signature: _____



**Public Works Bid No. 2019-001
Canyon Road Water Line Extension
PRE-BID MEETING
AGENDA
March 13, 2019**

1. Sign-in sheet and introductions
2. Project scope: Installation of 18-inch C-900 PVC (approximately 690 linear feet) waterline from the south side of McKinley Channel along Canyon Road (parking lot) crossing Washington Avenue, Washington Park, 1st Street, and finally connecting to an existing 18-inch waterline located within the Cemetery. The installation will cross existing utilities (gas, electric lines, fiber optic lines, potable water, reuse water, and sanitary sewer); the existing crossing reuse and potable waterlines will be lowered concurrently with the 18-inch line installation. The sanitary sewer line(s) are expected to be at sufficient depth to avoid potential vertical conflicts. Installation across paved streets and parking lots will require pavement removal and patching, sidewalk removal and replacement, curb and gutter removal and replacement, and concrete median removal and replacement.
3. This project will tie into the Corps of Engineers McKinley Channel project. There may be coordination with Pate Construction, depending upon the timing of the work.
4. The licensing requirement in the Advertisement was in error. GF-9 or GF-98 is the appropriate CID classification for the utility work.
5. Schedule: 60 calendar days to Substantial Completion 10 days to Final Completion (Section 8, Page 2).
6. BID OPENING is Tuesday, April 2nd at 1:30 pm in Commission Chambers at City Hall. Bidder questions must be submitted by 4:00 pm March 21. Questions received after that time will not be answered. Bidder questions must be directed to Purchasing either via fax at 575.439.4117 or via email to bpyeatt@ci.alamogordo.nm.us. Questions submitted will be answered by written addendum and will be binding.
7. Ten percent (10%) bid preference for local bidders is applicable for this project (See Section 2, Article 30.0). Section 2, Articles 33.0 and 34.0 cover In-State Preference and Resident Veterans Preference. Resident Veterans Preference Certification is in Section 7. A Bidder must specify which preference they would claim if qualifying for more than one. The preference values are not cumulative. Bidder must meet criteria at time of bid opening.
8. Section 2, Article 17.0 lists documents that must be submitted with the bid package.
9. For Reclaimed Water Rates contact the Water Billing Department at 575.439.4288. Locations of Reclaimed Water Hydrants are listed in Article 01-002.1 (3.0), page 6.
10. Wage Rates apply. Certified payrolls will be required and can be submitted vial email.
11. Gas Lines in project area – need to pothole; will need to deflect water lines around
12. See General Note 24 – this will include replacing disturbed landscaping at the cemetery

Public Works Bid No. 2019-001
Canyon Road Water Line Extension

Pre-Bid Meeting

March 13, 2019

SIGN IN SHEET

NAME	ORGANIZATION	CONTACT INFO
Nancy Beshaler	City of Alamogordo	575.439.4230
Rusty Payne <i>RWP</i>	Smith Engineering	
David Nunnelley	CoA	
<i>Rosann Medina</i>	<i>Total Contracting</i>	<i>(505) 800-7156</i>
<i>Erik Himmelberg</i>	<i>Pate Construction</i>	<i>(719) 415-0327</i>
<i>RICK ROOT</i>	<i>Apple Mountain</i>	<i>(505) 705-0578</i>
<i>Dean Terrell</i>	<i>Cherokee Ent</i>	<i>575-434-2347</i>
<i>ERNIE TENCARIS</i>	<i>Timberland Const Inc</i>	<i>575-313-5140</i>
<i>Chris Bouvet</i>	<i>Timberland Const. Inc</i>	<i>575-323-4093</i>
<i>Ed Boles</i>	<i>General Hydro-nics, Inc</i>	<i>575-470-1403</i>
<i>Charlie Martin</i>	<i>General Hydro-nics ^{VT}</i>	<i>575-430-5727</i>