



PURCHASING DIVISION

901 Broadway, N.E. • Knoxville, TN 37917-6699
 865.403.1133 • Fax 865.594.8858
 800.848.0298 (Tennessee Relay Center)
 Email: purchasing@kcdc.org
<http://www.kcdc.org/en/DoingBusiness.aspx>

Addendum

SOLICITATION NAME	Demolition on Payne Avenue Q1436	ADDENDUM NUMBER	1	DATE	04-28-14
--------------------------	----------------------------------	------------------------	---	-------------	----------

KCDC is providing this addendum to answer questions that have been raised about this solicitation. To aid in readability, the questions are in black and the answers are in **bold** and the answers follow immediately below.

Q1	Please clarify what trees are to remain.
	The trees/shrubs to remain are marked with yellow caution tape. All <u>unmarked</u> trees and shrubs are to be removed.
Q2	Describe the fencing to be done.
	Fabric to be used must meet ASTM A 116, Design Number 1047-6-11, with Class 3 coating. As an alternative, vendors may use aluminum coated steel that meets the requirements of ASTM A 584, Design Number 1047-6-11.
Q3	Are we to preserve the front door?
	The vendor shall remove the front door and frame from the building for reuse. The door and frame may be set aside to the north of the grubbing area. Cover the door with plastic so as to minimize water damage.