



**GENERATOR AND AUTOMATIC TRANSFER SWITCH FOR CITY HALL**  
INVITATION TO BID – REQUISITION NO. 2017-0616

ADDENDUM NO. THREE (3) – DATED JUNE 13, 2017

The information given in this addendum is in addition to or supersedes conflicting information to the invitation to bid and is hereby made a part of the request.

---

**Question #1:** What do we do with the old generator and transfer switch once removed?

**Answer:** The City will keep the old generator for surplus. Please note that the purchase of a new transfer switch has been removed from the bid per Addendum No. 2.

---

**Question #2:** Will permit fees be required to be paid by contractor?

**Answer:** No fees will be charged, but the Contractor will have to follow the City's standard permitting process to include inspections by the Building Department, if applicable.

---

**Question #3:** Please confirm that this is a tax free project.

**Answer:** Confirming that this is a tax free project. Tax exempt documentation will be provided upon request.

---

**Question #4:** Do we need to replace the existing sealtight flex conduit from the existing ATS to Generator?

**Answer:** Yes, the Contractor will need to replace the existing sealtight flex conduit.

---

**Question #5:** It does not appear that the existing cables from ATS to generator include a ground wire. Do we need to install one?

**Answer:** Yes, the Contractor will need to install a ground wire from the new Generator to the existing ATS.

---

**Question #6:** Do we need to provide a ground ring for the new generator and bond it to existing service ground?

**Answer:** Yes, the contractor will need to install a ground ring and bond it to existing service ground.

---

**Question #7:** Can we utilize existing battery charger and block heater circuit?

**Answer:** Yes, the Contractor may use existing circuits for the battery charger and block heater.

---

**Question #8:** Is there a DBA Level you want to meet at 7 meters or 23 feet for the generator enclosure?

**Answer:** No, there is no specified DBA Level to be met, but sound attenuation must be suitable for a generator placed in close proximity to an office building.

---

Please be sure to acknowledge receipt of this addendum on your bid form.