



GENERATOR AND AUTOMATIC TRANSFER SWITCH FOR CITY HALL
INVITATION TO BID – REQUISITION NO. 2017-0616

ADDENDUM NO. ONE (1) – DATED MAY 31, 2017

The information given in this addendum is in addition to or supersedes conflicting information to the invitation to bid and is hereby made a part of the request.

Under “Minimum Specifications,” Section C-1, Item 29 is amended to read as follows:

Fuel Tank – Dual Wall Sub-Base, 10 Amp Battery Charger, **72 Hours Minimum Capacity**

Please be sure to acknowledge receipt of this addendum on your bid form.