



The Town of Summerville  
200 S. Main Street  
Summerville, South Carolina 29483  
843-851-4215  
[KCollins@summervillesc.gov](mailto:KCollins@summervillesc.gov)

June 14, 2021

## Summerville Fire Rescue Station 6

### Q&A

1. The report states the requirement for earthquake drains and previous questions were answered as N/A. Is that because the information is not available at this time or the Town does not believe that earthquake drains are required? **N/A at the time**
2. The geotech report states foundations may experience a complete loss of bearing due to liquidation. If earthquake drains are provided as a mitigation measure, will this satisfy/ prevent the possibility of complete loss of bearing below the foundation? We want to make sure EQ drains will mitigate this issue and we don't need to have piles. **Shallow foundations with earthquake drains**
3. Does the Town expect the Offeror/Bidder to carry the cost for an additional geotech firm in our proposal or can the findings of the S&ME report, included in the RFQ documents, be integrated in our design? **S&ME report can be used**