



Oconee County Board of Commissioners

Addendum 2

DATE: January 14, 2021
TO: All Prospective Bidders/Offerors
FROM: Finance Director
RE: Addendum 2, ITB# 21-12-011 Bridge Repairs

The following changes are to be incorporated into the solicitation documents dated **December 30, 2020**. All those receiving this addendum should modify their documents to show the below described changes.

1. **Please exclude bridge on Mars Hill Road over Barber Creek (Serial No. 219-0013-0-D) from the Scope of Work.**
2. **Attached you will find the Bridge Inspection Report.**
3. **Attached you will find the sign-in roster for the Mandatory Pre-Bid Meeting.**
4. **Below you will find a hyperlink to the 2017 Inspection Report for each bridge.**
 - a. <https://bridgereports.com/1100839>
 - b. <https://bridgereports.com/1100843>
 - c. <https://bridgereports.com/1100848>
 - d. <https://bridgereports.com/1100861>
 - e. <https://bridgereports.com/1100871>
 - f. <https://bridgereports.com/1100872>
 - g. <https://bridgereports.com/1100877>
 - h. <https://bridgereports.com/1100878>
 - i. <https://bridgereports.com/1100882>

All questions shall be directed to the Owner Contact Jessica Ellis, Procurement Officer.

Email: ocbids@oconee.ga.us.

(END OF ADDENDUM 2)

Please note addendum 2 on the addenda acknowledgement form located in the ITB package.

County Bridge Report

Bridge Serial Number	Facility Carried by Structure	Features Intersected	Location	Priority	Comments
219-0007-0	Old SR 15	McNutt Creek	Decktop and Underside	B	Repair spalls with exposed rebar in spans 2 and 4
219-0011-0	Mars Hill Road	McNutt Creek	Deck	B	Seal shrinkage cracking in the deck
219-0017-0	Simonton Bridge Road	Middle Oconee River	Bearing	C	Clean and paint bearings at bent 3
			Cap	B	Repair spall with exposed rebar in cap at bent 3
			Deck	B	Repair spalling in the edgebeams with exposed rebar in span 4
219-5005-0	Malcom Bridge Road	Barber Creek	Deck Joints	C	Clean and seal the deck joints
219-5021-0	McRee Gin Road	Porters Creek	Outlet	B	Repair crack in outlet wing
219-5022-0	McRee Mill Road	Porters Creek	Barrel	B	Repair honeycombing in culvert barrel walls and wing walls in barrel 3
			Wing Wall	C	Repair cracking in rear inlet wing wall
219-5028-0	Barnett Shoals Road	Shoal Creek	Wing	B	Repair crack in the forward inlet wing
219-5029-0	Clotfelter Road	Barber Creek	Deck	B	Seal the cracking in the deck in span 1
			Deck Joints	C	Clean and seal the deck joints
219-5035-0	Epps Bridge Parkway	McNutt Creek	Abutment 4	C	Need to clean and seal the deck joint at abutment 4



Mandatory Pre-Bid Meeting Sign-In Roster

Requesting Department: Public Works

ITB Number: 21-12-011

Date/Time: January 12, 2021 @ 10:00 AM

Description: Bridge Repairs

PLEASE PRINT INFORMATION & ATTACH A BUSINESS CARD

COMPANY REPRESENTATIVE	COMPANY NAME & ADDRESS	PHONE/EMAIL
Jessee Williamson	E&D Contracting	(912) 271-7801 jessee78@gmail.com
Oscar Corredor	Gosalia Concrete Co.	(305) 797-6088 ocorredor@gosaliaco.com
Mark Williams	Williams Contracting Co., LLC	(404) 694-5381 mark@williamscco.com
Michael Boyle	McCarthy Improvement	(864) 918-6126 mboyle@mccarthyimprovement.com
David Ledford	Suncoast Restorations & Waterproofing	(404) 993-2244 dledford@suncoast-group.com
Karli Beglan	Southern Road & Bridge	(727) 916-2679 KBeglan@SouthernRB.com
Melissa Guy	JHC Corporation	(770) 487-3258 melissa@jgc-corp.com
Karl Young	The L.C. Whitford Co, Inc.	(770) 346-0610 karlyoung@lcwga.com
Jarod Cheney		
Eric Ashley	Georgia Bridge & Concrete LLC	
Adam Layfield	Oconee County Water Resources	alayfield@oconee.ga.us
Michael Weathers	Oconee County Road Department	mweathers@oconee.ga.us
Wes Geddings	Oconee County Finance Department	wgeddings@oconee.ga.us