

ADDENDUM NO. 2
TO THE CONTRACT DOCUMENTS FOR
GIG EAST WALL REPAIRS
127 GOLDSBORO STREET SOUTH
CITY OF WILSON, NORTH CAROLINA
MAY 31, 2022

To All Bidders:

This addendum is issued to modify or clarify the previously issued bid documents and/or given for informational purposes and is herein made a part of the bid documents. This addendum must be acknowledged on the contract Bid Proposal Form. Failure to acknowledge this addendum may subject the bidder to disqualification of his bid.

It is the responsibility of all bidders and all individual subcontractors to adhere to the following modifications, clarifications and/or information:

1. Bidders to utilize updated Bid Proposal Form labeled Addendum No. 2, dated 5/31/2022.
2. Several areas require repair, which includes removal of embedded steel to at least one brick depth, removal of flashing at old roof line, removal of loose material along exterior parapet wall sections, removing broken masonry, and filling voids. The base bid shall include 750 SF of masonry patching and a unit price shall be provided for any adjustment to actual quantity. Similarly, the base bid shall include 18,450 LF of point & tuck mortar joints and a unit price shall be provided for any adjustment to actual quantity. Sealing openings and around penetrations shall be included in base bid.
3. Bids may be submitted electronically to steve@bartletteng.com; however, bidder is responsible for confirming delivery.
4. Contractor is responsible for all safety precautions necessary to protect property and people.
5. There are no restrictions on work hours at the site.
6. Water and electricity will be available at the site.
7. Owner will provide a laydown area at the site.
8. There are no known hazardous materials at the site, however the contractor is responsible for making their own determination.
9. A pre-colored Type N mortar, color approved by owner, will be acceptable.

END OF ADDENDUM NO. 2

Robert S. Bartlett, PE
Bartlett Engineering & Surveying, PC