



City of Framingham

Purchasing Department
150 Concord Street
Memorial Building • Room 123
Framingham, MA 01702
Tel: 508-532-5407 Fax: 508-532-5445

Jennifer A. Pratt
Chief Procurement Officer

Amy Putney
Procurement Administrator

Request for quotes #7522 Fire Alarm, Sprinkler and Fire Pump Services

Date: June 29, 2022

TO: Plan Holders
FROM: Amy Putney
SUBJECT: Addendum Two
OPENING TIME: NO CHANGE

With reference to #7522 please note the following:
Responses to additional questions

Please sign and include this sheet with your bid submission to signify receipt of this Addendum. **By my signature below, I acknowledge receipt of the following Addenda to this proposal:**

Dated ___/___/___

Signature: _____ Date: _____
Company: _____ Date: _____

**Addendum No. 2 to the
Contract Documents Entitled
“City of Framingham, Massachusetts,
Request for quotes Fire Alarm, Sprinkler and Fire Pump Services
June 29, 2022**

The following changes and additional information are hereby made part of the Contract Documents. Addendum No.2 consists of the following:

Question No.1 Page 1, #5 – is this referring to a fire drill? Or do all inspections have to be completed before 8:30am?

Response No.1 The testing of fire alarm is to be initiated for full fire test and completed by 8:30

Question No.2 To confirm, fire alarm systems/devices and fire pumps are to be tested annually, and sprinkler systems are semi?

Response No.2 Please see Form B on the pricing proposal which clearly defines the services that are to be included and which is annual and what is semiannual.

Question No.3 Page 1, #11 – are we to include the elevator inspection pricing on provided pricing sheet with fire alarm?

Response No.3 The elevator inspections vary in time from building to building this is service that is required per this bid to be available to conduct. This will be billed as additional service on per hour basis, please provide all costs per man hour for testing services. If there is minimum labor charge please make that clear.

Question No.4 Page 2, #13 – barcoding. Attached is an example of our inspection reports. We don't typically barcode, but we do list the component under "zone" to identify the device. Are we able to use the existing barcode # and enter it in the "zone" to identify?

Response No.4 The bar coding will remain labeled on our devices, the devices are to be identified on testing report.

Question No.5 Prevailing Wage – where should we enter PW labor rates on the bid?

Response No.5 Prevailing wage will be require only if the system is being repaired or worked on the and the prevailing wage will be provided at this time from the City.

Question No.5a And to confirm, the PW classification for sprinkler/pump would be **pipe fitter** and fire alarm would be **fire alarm repair/maintenance**, correct?

These classifications are on the prevailing wage for repairs or work being done, depending on what is to be repaired would determine classification.