



City of Framingham

Purchasing Department
150 Concord Street
Memorial Building • Room 123
Framingham, MA 01702
Tel: 508-532-5407 Fax: 508-532-5445

Jennifer A. Pratt
Chief Procurement Officer

Amy Putney
Procurement Administrator

Request for quotes #7522 Fire Alarm, Sprinkler and Fire Pump Services

Date: June 15, 2022

TO: Plan Holders
FROM: Amy Putney
SUBJECT: Addendum One
OPENING TIME: **NO CHANGE**

With reference to #7522 please note the following:

Responses to questions

Revised price sheet – see attached

Please sign and ***include this sheet with your bid submission*** to signify receipt of this Addendum. **By my signature below, I acknowledge receipt of the following Addenda to this proposal:**

Dated ___/___/___

Signature: _____
Company: _____

Date: _____
Date: _____

**Addendum No. 1 to the
Contract Documents Entitled
"City of Framingham, Massachusetts,
Request for quotes Fire Alarm, Sprinkler and Fire Pump Services
June 15, 2022**

The following changes and additional information are hereby made part of the Contract Documents.
Addendum No.1 consists of the following:

Question No.1 Are the sprinkler systems Wet or Dry systems?

Response No.1 All are wet, we have one facility with both ...15 devices wet and 10 dry (Village hall)

Question No.2 On the price sheet, the Memorial Building was left off.

Response No.2 See new price sheet attached

Question No.3 Are there any buildings that will require a lift to access the devices and if so how high are they

Response No.3 No lift required

Form B: Pricing Proposal

Callahan Center- 535 Union Avenue		
Pricing	Year 1	Year 2
Fire Alarm System: Test & Inspection	\$	\$
Sprinkler System: Test & Inspection (Semi-Annual)	\$	\$
Total	\$	\$

CPFM Office – 10 Nicholas Road		
Pricing	Year 1	Year 2
Fire Alarm System: Test & Inspection	\$	\$
Total	\$	\$

Cushing Chapel- 60 Dudley Road		
Pricing	Year 1	Year 2
Fire Alarm System: Test & Inspection	\$	\$
Total	\$	\$

Danforth Building- 123 Union Avenue		
Pricing	Year 1	Year 2
Fire Alarm System: Test & Inspection	\$	\$
Total	\$	\$

Fire Station #2 – 75 A Street		
Pricing	Year 1	Year 2
Fire Alarm System: Test & Inspection	\$	\$
Sprinkler System: Test & Inspection (Semi-Annual)	\$	\$
Total	\$	\$

Fire Station #3- 10 Loring Drive		
Pricing	Year 1	Year 2
Fire Alarm System: Test & Inspection	\$	\$
Sprinkler System: Test & Inspection (Semi-Annual)	\$	\$
Total	\$	\$

Main Library – 49 Lexington Street		
Pricing	Year 1	Year 2
Fire Alarm System: Test & Inspection	\$	\$
Sprinkler System: Test & Inspection (Semi-Annual)	\$	\$
Total	\$	\$

Form B: Pricing Proposal

McAuliffe Branch Library- 746 Water Street		
Pricing	Year 1	Year 2
Fire Alarm System: Test & Inspection	\$	\$
Sprinkler System: Test & Inspection (Semi-Annual)	\$	\$
Total	\$	\$

Memorial Building – 150 Concord Street		
Pricing	Year 1	Year 2
Fire Alarm System: Test & Inspection	\$	\$
Total	\$	\$

Pearl Street Garage - 3 Pearl Street		
Pricing	Year 1	Year 2
Fire Alarm System: Test & Inspection	\$	\$
Total	\$	\$

Police Station - 1 William H. Welch Way		
Pricing	Year 1	Year 2
Fire Alarm System: Test & Inspection	\$	\$
Sprinkler System: Test & Inspection (Semi-Annual)	\$	\$
Fire Pump: Test & Inspection (Annual)	\$	\$
Total	\$	\$

Village Hall - 2 Oak Street		
Pricing	Year 1	Year 2
Fire Alarm System: Test & Inspection	\$	\$
Sprinkler System: Test & Inspection (Semi-Annual)	\$	\$
Total	\$	\$

Grand Totals	
Year 1	Year 2
\$	\$

The City reserves the right using this bid to conduct repairs on systems up to \$35,000.00. Any deficiency/repair work needed/required will be priced at prevailing wage plus materials and pricing will be presented to the City to approve such deficiencies/repairs to bring the systems to compliance.

Callahan Center – 535 Union Avenue

Fire Alarm System – Gamewell Evax 100		Sprinkler System	
<u>Device Type</u>	<u>Quantity</u>	<u>Category</u>	<u>Quantity</u>
Battery	6	Device	4
Control Panel	2	Alarm	3
Duct Detector	6	Valve	6
Expander Panel	1	Hose	1
Pull Station	10	Sprinkler	1
Smoke Detector	31		
Total	56	Total	15

Fire Station #2 – 75 A Street

Fire Alarm System – Simplex 4010ES		Sprinkler System	
<u>Device Type</u>	<u>Quantity</u>	<u>Category</u>	<u>Quantity</u>
Battery	2	Device	9
CO Detector	4	Alarm	6
Communicator	1	Valve	9
Control Panel	1	Hose	1
Duct Detector	1	Sprinkler	1
Heat Detector	2		
Horn/Strobe	1		
Pull Station	3		
Smoke Detector	25		
Special Control	1		
Total	41	Total	26

Fire Station #3 Headquarter – 10 Loring Drive

Fire Alarm System – FCI FC-72		Sprinkler System	
<u>Device Type</u>	<u>Quantity</u>	<u>Category</u>	<u>Quantity</u>
Battery	2	Device	4
Control Panel	1	Alarm	5
Duct Detector	2	Valve	8
Masterbox	1	Hose	1
Pull Station	11	Sprinkler	1
Smoke Detector	26		
Total	43	Total	19

Main Library – 49 Lexington Street

Fire Alarm System – Siemens 922FV		Sprinkler System	
<u>Device Type</u>	<u>Quantity</u>	<u>Category</u>	<u>Quantity</u>
Annunciator	1	Device	3
Battery	6	Alarm	17
CO Detector	1	Valve	23
Communicator	1	Hose	6
Control Panel	1	Sprinkler	1
Duct Detector	2		
Expander Panel	1		
Heat Detector	4		
Masterbox	1		
Power Supply	1		
Pull Station	11		
Smoke Detector	28		
Voice Evacuation	1		
Total	59	Total	50

McAuliffe Branch Library – 746 Water Street

Fire Alarm System - Notifier NFS2-640		Sprinkler System	
<u>Device Type</u>	<u>Quantity</u>	<u>Category</u>	<u>Quantity</u>
Annunciator	1	Device	3
Battery	2	Alarm	1
Communicator	1	Valve	5
Control Panel	1	Hose	1
Duct Detector	2	Sprinkler	1
Heat Detector	1		
Pull Station	5		
Smoke Detector	8		
Total	21	Total	11

Police Station – 1 William H. Welch Way

Fire Alarm System – EST LSS4/36		Sprinkler System	
<u>Device Type</u>	<u>Quantity</u>	<u>Category</u>	<u>Quantity</u>
Battery	4	Device	6
Control Panel	1	Alarm	9
Duct Detector	2	Valve	24
Heat Detector	2	Hose	10
Power Supply	1	Pump	5
Pull Station	16	Sprinkler	1
Smoke Detector	25		
Total	51	Total	55
Fire Pump – Peerless- 6AEF11			

Village Hall – 2 Oak Street

Fire Alarm System – Firelite ES-200X		Sprinkler System	
<u>Device Type</u>	<u>Quantity</u>	<u>Category</u>	<u>Quantity</u>
Annunciator	1	Device	7
Battery	2	Alarm	6
Communicator	1	Valve	9
Control Panel	1	Hose	1
Duct Detector	2	Pump	1
Heat Detector	1	Sprinkler	1
Horn/Strobe	9		
Pull Station	4		
Smoke Detector	7		
Strobe	3		
Total	31	Total	25

CPFM Office – 10 Nicholas Road

Fire Alarm System – Mircom FA-1000	
<u>Device Type</u>	<u>Quantity</u>
Battery	2
Communicator	1
Control Panel	1
Heat Detector	6
Pull Station	5
Smoke Detector	15
Strobe	1
Total	31

Cushing Chapel – 60 Dudley Road

Fire Alarm System – FCI 72 Series	
<u>Device Type</u>	<u>Quantity</u>
Battery	2
Beam Detector	1
Communicator	1
Control Panel	1
Heat Detector	15
Pull Station	3
Smoke Detector	3
Total	26

Danforth Building – 123 Union Avenue	
Fire Alarm System – FCI 72	
<u>Device Type</u>	<u>Quantity</u>
Annunciator	1
Battery	8
Control Panel	1
Expander Panel	3
Heat Detector	14
Horn/Strobe	1
Pull Station	23
Smoke Detector	57
Total	108

Memorial Building – 150 Concord Street	
Fire Alarm System – Mircom FX-2017-12ADS	
<u>Device Type</u>	<u>Quantity</u>
Annunciator	1
Battery	10
Control Panel	1
Elevator Recall	3
Heat Detector	46
Masterbox	1
Power Supply	4
Pull Station	13
Smoke Detector	53
Total	132

Pearl Street Garage – 3 Pearl Street	
Fire Alarm System – FCI FC-72	
<u>Device Type</u>	<u>Quantity</u>
Battery	2
Control Panel	1
Heat Detector	6
Pull Station	9
Total	18

THIS PAGE IS MANDATORY

REFERENCES

List three (3) references that you have provided similar work and service to within the last twelve (12) months
(Only correct contact names and phone numbers will be acceptable).

Company/Municipality: _____

Address: _____

City, State, Zip Code: _____

Telephone Number: _____

Contact Person: _____

Contact Email Address: _____

Company/Municipality: _____

Address: _____

City, State, Zip Code: _____

Telephone Number: _____

Contact Person: _____

Contact Email Address: _____

Company/Municipality: _____

Address: _____

City, State, Zip Code: _____

Telephone Number: _____

Contact Person: _____

Contact Email Address: _____
